

Certificate of Assessment

- 2 Component **BPG Range of Enclosures**
- | | | | | | | |
|---------|--------------|--------------|--------------|--------------|---------------|--------------|
| | BPG1 | BPG2 | BPG3 | BPG4 | BPG4.5 | BPG5 |
| Models: | BPG6 | BPG7 | BPG8 | BPG9 | BPG10 | BPG11 |
| | BPG12 | BPG13 | BPG14 | BPG15 | | |
- 3 Manufacturer **Abtech Limited**
- 4 Address **Sanderson Street
Lower Don Valley
Sheffield S9 2UA
UK**
- 5 The components specified have been evaluated against the requirements of the standard specified in Section 7.
- 6 This evaluation is based on the following documents:
Report R108A
- 7 Specification: **IEC 60529:1989+A1:1999+A2:2013** **BS EN 60529:1992+A2:2013**
Petrobras Technical Specification: ET-3010-00-1200-941-PPC-00
- 8 **IP66W** **IP67**
- 9 Assessment This is to certify that, on the basis of the testing carried out, that the above model range of BPG enclosures were considered to comply with the requirements listed in section 8, with respect to the Ingress Protection standards listed in section 7.
- 10 Date: 5th February 2014

